

TEST CERTIFICATE

for the slip resistance of floor coverings
according to DIN EN 16165, Annex A

Tested material: **Coating**

Article description: Plastifloor bedding fine grain
Type of material: PMMA floor coating
Material composition: Primer: Plastifloor 112 (0.5 ltr./m²), lightly sprinkled with quartz sand 0.6-1.2 mm;
Coating: Plastifloor 418 (1.2 ltr./m²), 1:1 SL filler, fully sprinkled with colour quartz KFC RED (0.6-1.2 mm);
Sealer: Plastifloor 526 2-fold (0.3 ltr./m²)
Colour description: KFC Red - Mix: red, grey, anthracite speckled
Dimensions: Length and width variable, test sample: 1000 x 500 x 3 mm
Surface description: slightly fine-grained (even, coarse-grained structured)
Producer/supplier: Plasti Chemie Produktionsgesellschaft mbH
Falgardring 1
08223 Falkenstein/Vogtland

Client: Plasti Chemie Produktionsgesellschaft mbH
Falgardring 1
08223 Falkenstein/Vogtland

Certificate No.: 99292303.001e

Sample receipt: 14.04.2023

Test date: 02.05.2023

Sampling: Sent by the customer to the research institute

Test method: **DIN EN 16165** (edition 02/2023)
"Determination of slip resistance of pedestrian surfaces - Methods of evaluation"
Annex A – Barefoot ramp test
Delivery of the test material has been effected in ready-to test surface condition.

Test result: Angle value α_{barefoot} : **32°**

Assessment: **Slip resistance assessment group: C**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director

Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 30.05.2023
Schu/ke

This test certificate is only valid for the products tested an identical with the test sample. No measurement uncertainties are taken into account for the classification according to the test basis. The test certificate is issued for a period of 5 years (related to the test date). Publication and duplication of the test certificate is only permitted in unabridged form.



– Institut für Wand- und Bodenbeläge –
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00 aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

